

State / Regional / District / Public Health Laboratory ... Ahilya, Doga

E-mail-ID : dphlab@gmail.com

Phone No. : (0241) 2354038

**REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES**

Date of Collection :- 18.03.25 Date of Receipt :- 18.03.25 Date of Examination :- 18.03.25 onwards  
(All the Analytical Results are in mg./litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1) <u>प्रतिफल</u> <u>नोट के साथ</u>	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1	Physical Appearance	<u>clear</u>			-	-
2	Odour	<u>odourless</u>			Agreeable	Agreeable
3	Turbidity (as N.T.U.)	<u>0.1</u>			1.0	5.0
4	pH Value	<u>7.2</u>			6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	<u>81</u>			250	1000
6	Nitrates (as $\text{NO}_3$ )	<u>1.1</u>			45	No relaxation
7	Total Hardness (as $\text{CaCO}_3$ )	<u>60</u>			200	600
8	Alkalinity (as $\text{CaCO}_3$ )	<u>51</u>			200	600
9	Total Dissolved Solids	<u>190</u>			500	2000
10	Iron (as Fe)	<u>0.03</u>			0.3	No relaxation
11	Fluoride (as F)	<u>0.37</u>			1.0	1.5
12	Other Tests (If any)	<u>—</u>				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- \* This report is restricted only for the Sample/s Is Submitted to this Laboratory.
- \* This Samples/s Is / are not Collected by this Laboratory.

(RTO)

Secretary  
Shri Balasaheb Wani Central School  
A/p. Ganegaon, Tal. Rahuri, Dist. A'nagar

Principal



## REMARKS

A) Sample No. (s) 1 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) — Contains —

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) — Contains —

Hence, this / these water Sources is/ are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 1380

Date: 18.03.25

Forwarded With Compliments To: —Principal

Shri Balasaheb Wani Central School & Jr. College,  
Ganegaon, Tal. Rahuri, Dist. A. Nagar.

With reference to letter No.: SBWCOPI/2024-25 Dated: 18.03.25  
95

Fees Rs.: 940/-Receipt No. and Date: 436273, 18.03.2025

B. B. B.  
Junior Scientific Officer  
District Public Health Laboratory  
Ahmednagar

D. V.  
Secretary

Principal  
Shri Balasaheb Wani Central School  
A/p. Ganegaon, Tal. Rahuri, Dist. A. Nagar



APPENDIX – VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

No. PASG/355/2025

Date – 20/03/2025

It is certified that an inspection team headed by Dr. Adbhai P. G. Medical Officer ( Class 2) Primary Health Center Guha Tal. Rahuri Dist. Ahilyanagar inspected the Shri Balasaheb Wani Central School Ganegaon Po. Guha Tal. Rahuri Dist. Ahilyanagar (MH) 413706 on 20/03/2025 and found that the Shri Balasaheb Wani Central School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.


The above valid for a period of From 20/03/2025 to 19/03/2027.

Signature with Seal : 


Name : वैद्यकीय अधिकारी (वर्ग-२)

Designation : प्राथमिक आरोग्य केंद्र, गुहा  
तालुका-राहुरी, जिल्हा अहमदनगर

To,  
Prasad Gramin Shikshan Sanstha's,  
Shri Balasaheb Wani Central School,  
Ganegaon, Po. Guha, Tal. Rahuri, Dist. Ahilyanagar (MH) 413706

  
Secretary

Shri Balasaheb Wani Central School  
A/p. Ganegaon, Tal. Rahuri, Dist. A'nagar

  
Principal